## NATIONAL STANDARD OF THE PEOPLE'S REPUBLIC OF CHINA

中华人民共和国国家标准

Code for Erection and Acceptance of

**Automation Instrumentation Engineering** 

自动化仪表工程施工及验收规范

GB 50093-2002

Chief Editorial Department: Association of Petroleum and Chemical Industry of China

Approved Department: Ministry of Construction of PRC, China

Date of Implementing: March 1st, 2003

## NOTICE

This code is written in Chinese and English. The Chinese text shall be taken as the ruling one in the event of any inconsistency between the Chinese text and the English text.

# Notice from the Ministry of Construction of People's Republic of China

No. 99

## Notice from the Ministry of Construction for publishing the Code for Erection and Acceptance of Automation Instrumentation Engineering

Hereby the Code for Erection and Acceptance of Automation Instrumentation Engineering is ratified as a national standard, the number is GB 50093-2002, and it will be implemented from March 1<sup>st</sup>, 2003 on. For it, articles 1.0.3, 4.1.3, 4.5.6, 5.2.11, 5.5.1(3)(4), 5.5.2, 6.1.7, 6.1.15, 6.1.17, 7.1.3, 7.2.4, 7.6.5, 8.1.1, 8.1.4, 8.1.5, 8.1.6, 8.1.7, 8.1.9, 8.1.10, 8.1.11, 8.2.5, 8.3.1, 9.1.2, 9.1.6(12), 9.1.7, 9.1.8(2)(4), 9.1.9, 9.1.11, 9.2.1, 10.1.2, 11.1.5, 11.1.10 are mandatory documents, and shall be executed strictly. The former Code for Erection and Acceptance of Industrial Automation Instrumentation Engineering GBJ 93-86 is abolished at the same time.

The Research Institute for Quota of Standards under the Ministry of Construction is to organize the Planning Publishing House of China to publish and issue this Code.

Ministry of Construction of People's Republic of China Jan. 10<sup>th</sup>, 2003

#### **Preface**

This Code is revised, according to Construction Standard No. [1997] 108 document from the Ministry of Construction—the "Notification for Printing and Publishing the Plan for Making up and Revising the National Standard for Engineering Construction in 1997", by the former Ministry of Chemical Industry, which acts as the editing department, jointly with concerned departments of the Ministry of Metallurgy, Machinery, and SinoPec, etc., based on the former national standard, the Code for Erection and Acceptance of Industrial Automation Instrumentation Engineering GBJ 93-86. This Code includes 12 chapters as General, Terminology, Erection Preparation, Installation of Energy Components, Installation of Instrumentation equipment, Installation of Instrumentation lines, Installation of Instrumentation Piping, Degreasing, Electric Anti-explosion and Earthing, Protection, Test on Instruments and Acceptance of Engineering, etc.

In the name of the new Code, the "industrial automation instrumentation engineering" is changed to be "automation instrumentation engineering", this has enlarged the applicable scope. It is newly added two chapters as the terminology, and erection preparation, and four sections as mechanical measuring & inspecting instrument, other inspecting instrument, control instrument and comprehensive control system, test of comprehensive control system, etc. Some chapters of the former Code are adjusted.

During the revision, the revising team for the Code has made wide investigation and study, and has summarized the practical experiences in erection of automation instrumentation works (engineering) of China, meanwhile, it has referred to a lot of documentations and engineering technical materials about automation instrumentation eingineerings both from home and abroad, as well as the revisions for concerned national standards relative with instrumentation products, pipe erection, electric erection and electric anti-explosion, and asked widely opinions from concerned organization units all over China for engineering erection, engineering design, production of petrochemical products, manufacturing of instrumentation devices and materials, quality supervision & inspection from such sectors as chemical industry, petrochemical industry, metallurgy, machinery and electricity, etc. The revising team fixed the draft after sorting out, discussing and reviewing the opinions collected.

When executing the Code, the organization units concerned would better summarize carefully the experiences and accumulate technical materials in conjunction with engineering practice. If any points which shall be modified and complemented were found, please send the opinions and concerned technical materials to the Secretary Department of the Commission of Chemical Industry Engineering under the Standardization Association for Engineering Construction of China (Address: No.16 Building, Block IV, An-Hui-Li, Ya-Yun-Cun, Beijing, Postal code: 100723, phone: 84885096) for reference in revision in future. The National Standardization Management Center of Construction for Chemical Industry (phone (fax):0311-5886241) will be responsible for explaining the Code.

Website: <a href="http://www.hgsgbiaozhun.com">http://www.hgsgbiaozhun.com</a>
E-mail: <a href="mailto:webmaster@hgsgbiaozhun.com">webmaster@hgsgbiaozhun.com</a>

Organization units editing the Code and those participating in editing the Code as well as names of drafters:

Editing organization unit: National Standardization Management Center Station of Construction

for Chemical Industry

Units participating in the editing: No.4 Construction Company of Chemical Engineering of China

No.10 Construction Company of Sinopec Group

No.22 Metallurgy Construction Company of China

No.9 Construction Company for Chemical Engineering of China

Nanyang Anti-explosion Electric Research Institute

Main drafters: Tongxing Zhang, Zhongde Mao, Zuqing Yan, Changsen Yan, Qiuke Gao, Zhiwen Hou, Gang Zhang

## **Contents**

l	Ge	neral	I
2	Te	rminologies	2
3	Ere	ection Preparation	7
	3.1	Erection Technology Preparation	7
	3.2	Inspection and Storage of Instrumentation Equipment and Materials	7
4	Ins	tallation of Taps	
	4.1	General Specification	9
	4.2	Temperature Tap	9
	4.3	Pressure Tap	10
	4.4	Flow Tap	10
	4.5	Material-Level Tap	12
	4.6	Analyzing Tap	13
5	Ins	tallation of Instrumentation Equipment	14
	5.1	General specification	14
	5.2	Instrument Board, Cabinet and Box	15
	5.3	Temperature Measuring Instrument	17
	5.4	Pressure Measuring Instrument	17
	5.5	Flow Measuring Instrument	17
	5.6	Material-level Measuring Instrument	
	5.7	Measuring Instrument for Mechanical Value	20
	5.8	Measuring Instrument for Component Analysis and Physical Characteristics	
	5.9	Other Measuring Instrument	
	5.10		
	5.11	Control instrument and Comprehensive Control System	
	5.12		
6	Ins	tallation of Instrumentation Line	
	6.1	General specification	
	6.2	Making and Installation of A Stand	
	6.3	Installation of Cable Chute	
	6.4	Installation of Protective Tube	
	6.5	Laying of Cable and Wire	
	6.6	Wiring of Instrumentation Line	
7		tallation of Instrumentation piping	
	7.1	General Specification	
	7.2	Measuring Piping	
	7.3	Pipe for Pneumatic Signal	
	7.4	Air Piping	
	7.5	Hydraulic Piping	
	7.6	Instrumentation piping in Switchboard, Cabinet and Box	
	7.7	Testing on Piping	38

8 D	Degreasing	40			
8.1	General specification	40			
8.2	Degreasing Way	41			
8.3	Inspecting the Degreasing	41			
9 E	lectrically Explosion Protection and Earthing	43			
9.1	Erection of Instrumentation in An Environment with Risk of Explosion and	l Fire Accident43			
9.2	Grounding (Earthing)	45			
10 P	rotection	47			
10.	I Isolation and Purging	47			
10.2	2 Anti-corrosion and Thermal Insulation	47			
10.3	3 Heat Tracing	48			
11 Te	est on Instrumentation	50			
11.	l General specification	50			
11.2	2 Calibrating and Testing of A Single Instrument	51			
11.3	3 Testing of Power Supply Devices for Instrumentation	53			
11.4	4 Testing on Comprehensive Control system	53			
11.5	5 Loop Test and System Test	54			
12 A	cceptance of the Engineering	57			
12.1	Condition for Hand-over Acceptance	57			
12.2	2 Hand-over Acceptance	57			
Apper	ndix A Min. Straight Pipe Length Required for A Throttling Component	59			
Terms Used in This Code					
Descr	Description of the Articles63				

#### 1 General

- 1.0.1 This Code is worked out for improving the erection technology and management level, guaranteeing the quality of automation instrumentation (hereinafter short as instrumentation) engineering.
- 1.0.2 This Code is applicable for the erection and acceptance of the industrial and civil instrumentation engineering.

This Code is not applicable for the installation works for instruments used at such places as manufacturing, storing and where using explosive materials as well as installation works for traffic tools, in-the-pit and meteorological instruments, etc.

- 1.0.3 The erection of an instrumentation engineering shall meet the design document and this Code, and shall meet the Installation & Operation Instructions of the product concerned. Any modification to the design shall be confirmed by the original designing unit.
- 1.0.4 The instrumentations and instrumentation taps directly mounted on the equipment and piping shall be erected according to the bordering for specialties in the design document.
- 1.0.5 The devices and materials adopted in the instrumentation engineering shall meet current national mandatory standard concerned.
- 1.0.6 The welding of instrumentation engineering shall meet current national standard, the Code for Erection and Acceptance of On-site Welding Works for Equipment and Industrial Piping, GB 50236-98.
- 1.0.7 In addition to this Code, the erection for the instrumentation engineering shall also meet current national mandatory standard concerned.



#### 北京文心雕语翻译有限公司

Beijing Lancarver Translation Inc.

### 完整版本请在线下单

或咨询:

TEL: 400-678-1309

00: 19315219

Email: info@lancarver.com

http://www.lancarver.com

### 线下付款方式:

1. 对公账户:

单位名称:北京文心雕语翻译有限公司

开户行:中国工商银行北京清河镇支行

账号: 0200 1486 0900 0006 131

2. 支付宝账户: info@lancarver.com

注:付款成功后,请预留电邮,完整版本将在一个工作日内通过电子 PDF 或Word 形式发送至您的预留邮箱,如需索取发票,下单成功后的三个工作日内安排开具并寄出,预祝合作愉快!

